

# Kidde Fire Protection NATURA™ (400 Series) Inert Gas System Component Description

## Unistrut® Cylinder Racking Components

### FEATURES

- For Approvals, see the “COMPATIBILITY” table.
- REACH and RoHS compliant

### DESCRIPTION

Use Unistrut®, a standardized formed structural system used in the construction and electrical industries for light structural support, as the base to which to connect the cylinder racking components. The racking system for the Kidde Fire Protection NATURA™ (400 Series) Inert Gas System is modular and can be adjusted to fit any number of cylinders in a variety of row and stack combinations.

### MATERIALS

Body: Steel  
Surface Treatment: Galvanized

### ORDERING INFORMATION

| Part Number  | Description                        | Wt (kg) |
|--------------|------------------------------------|---------|
| 01-8121-1000 | 80L Cyl Wall Bracket 1 Cyl 400mm   | 0.9     |
| 01-8122-1000 | 80L Cyl Wall Bracket 2 Cyl 650mm   | 1.6     |
| 01-8123-1000 | 80L Cyl Wall Bracket 3 Cyl 950mm   | 2.3     |
| 01-8124-1000 | 80L Cyl Wall Bracket 4 Cyl 1250mm  | 3.0     |
| 01-8125-1000 | 80L Cyl Wall Bracket 5 Cyl 1550mm  | 3.7     |
| 01-8126-1000 | 80L Cyl Wall Bracket 6 Cyl 1850mm  | 4.4     |
| 01-8121-1400 | 140L Cyl Wall Bracket 1 Cyl 440mm  | 1.0     |
| 01-8123-1000 | 140L Cyl Wall Bracket 2 Cyl 950mm  | 2.3     |
| 01-8125-1000 | 140L Cyl Wall Bracket 3 Cyl 1550mm | 3.7     |

### COMPATIBILITY

| Series   | DIOM P/N      | Approvals*   |
|--|---------------|--------------|
| Natura IGS system  | 06-237518-001 | LPCB, FM, UL |
| * For additional listings, contact Kidde Fire Protection |               |              |



Figure 1.




Figure 2.

### REFERENCE PARTS:

- Wooden Spacers, Clamping Bar:  
See P/N 03-8161/62/63-000
- Clamp for Cylinder: See P/N 01-8131-000
- Clamping Bolts: See P/N 01-8337-0100/0300
- End Cover: See P/N 01-8131-0002

This literature is provided for informational purposes only. Kidde-Fenwal, LLC believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. Kidde-Fenwal, LLC assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly. If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL, LLC, Ashland, MA 01721.

Kidde-Fenwal, LLC  
400 Main Street  
Ashland, MA 01721, USA

KFI U.K. Limited  
Station Road,  
Bentham, Lancaster, LA2 7NA, UK

Kidde Technologies  
Survey No. 28/2, 44/2 and 45  
Rasyani, Dandapta Road  
Raigad Maharashtra-410207, India