

Kidde Fire Protection

NATURA™ (400 Series) Inert Gas System

Component Description

Manifold Accessories

FEATURES

- For Approvals, see the “COMPATIBILITY” table.
- REACH and RoHS compliant

DESCRIPTION

Coupled manifolds together using the 2” BSP Manifold Coupling (P/N: 38-400020-100). Use the manifold end cap (P/N 38-400020-101) to close of the end of the manifold that does not connect to the system piping. Use the 3/4” end cap (38-400020-102) to cap off any unused stubs or check valves in a manifold. For example, if using an 8 stub, 2 row manifold and only needing to connect 7 cylinders, one stub or check valve would be capped off.



Figure 1. 2” BSPT Manifold Coupling



Figure 2. 2” BSPT Manifold End Cap



Figure 3. 3/4” BSP End Cap for 14mm Check Valve

COMPATIBILITY

Series	DIOM P/N	Approvals*
Natura IGS system	06-237518-001	LPCB, FM, UL
* For additional listings, contact Kidde Fire Protection		

ORDERING INFORMATION

Part Number	Description	Rating	Material	Approx. Weight
38-400020-100	2” BSPT Manifold Coupling	3000 lb	Plated Mild Steel	1.4 kg (3.1 lbs)
38-400020-101	2” BSPT Manifold End Cap	3000 lb		1.0 kg (2.2 lbs)
38-400020-102	3/4” BSP End Cap For 14mm Check Valve	300 bar		0.5 kg (1.1 lbs)

This literature is provided for informational purposes only. Kidde-Fenwal, LLC believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. Kidde-Fenwal, LLC assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly. If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL, LLC, Ashland, MA 01721.

Kidde-Fenwal, LLC
400 Main Street
Ashland, MA 01721, USA

KFI U.K. Limited
Station Road,
Bentham, Lancaster, LA2 7NA, UK

Kidde Technologies
Survey No. 28/2, 44/2 and 45
Rasyani, Dandapta Road
Raigad Maharashtra-410207, India